

November 03, 2016

Michael Anania
NYS School for the Deaf
401 Turin St
Rome, NY 13440

RE: Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Dear Michael Anania:

Enclosed are the analytical results for sample(s) received by the laboratory on October 14, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366518001	Room 508/Sink	Water	10/08/16 04:06	10/14/16 09:45
10366518002	Room 512/Sink	Water	10/08/16 04:13	10/14/16 09:45
10366518003	Room 510/Sink	Water	10/08/16 04:07	10/14/16 09:45
10366518004	Room 518/Sink	Water	10/08/16 04:14	10/14/16 09:45
10366518005	Room 515/Sink	Water	10/08/16 04:10	10/14/16 09:45
10366518006	Utility Sink Across From Nurse	Water	10/08/16 04:11	10/14/16 09:45
10366518007	Room 516/Sink	Water	10/08/16 04:15	10/14/16 09:45
10366518008	Room 503/Sink	Water	10/08/16 04:34	10/14/16 09:45
10366518009	Room 409/Sink	Water	10/08/16 04:35	10/14/16 09:45
10366518010	Room 411/Sink	Water	10/08/16 04:35	10/14/16 09:45
10366518011	Room 414/Sink	Water	10/08/16 04:39	10/14/16 09:45
10366518012	Room 415/Sink	Water	10/08/16 04:37	10/14/16 09:45
10366518013	D.F. By Room 415	Water	10/08/16 04:40	10/14/16 09:45
10366518014	Room 416/Sink	Water	10/08/16 04:36	10/14/16 09:45
10366518015	Room 417/Sink	Water	10/08/16 04:36	10/14/16 09:45
10366518016	Room 400/Sink	Water	10/08/16 04:41	10/14/16 09:45
10366518017	Room 402/Sink	Water	10/08/16 04:43	10/14/16 09:45
10366518018	Room 430/Sink	Water	10/08/16 04:45	10/14/16 09:45
10366518019	Room 431/Sink	Water	10/08/16 04:45	10/14/16 09:45
10366518020	Room 432/Sink	Water	10/08/16 04:46	10/14/16 09:45
10366518021	Room 421/Sink	Water	10/08/16 04:53	10/14/16 09:45
10366518022	Room 422/Sink	Water	10/08/16 04:53	10/14/16 09:45
10366518023	Room 423/Sink	Water	10/08/16 04:52	10/14/16 09:45
10366518024	Room 424/Sink	Water	10/08/16 04:50	10/14/16 09:45
10366518025	D.F. By Room 424	Water	10/08/16 04:51	10/14/16 09:45
10366518026	Room 426/Sink	Water	10/08/16 04:49	10/14/16 09:45
10366518027	Room 600/Sink	Water	10/08/16 04:17	10/14/16 09:45
10366518028	Room 604/Sink	Water	10/08/16 04:17	10/14/16 09:45
10366518029	Room 614/Sink	Water	10/08/16 04:22	10/14/16 09:45
10366518030	Room 615/Sink	Water	10/08/16 04:21	10/14/16 09:45
10366518031	Room 616/Sink	Water	10/08/16 04:20	10/14/16 09:45
10366518032	Room 617/Sink	Water	10/08/16 04:20	10/14/16 09:45
10366518033	Room 612/Sink	Water	10/08/16 04:22	10/14/16 09:45
10366518034	Room 610/Sink	Water	10/08/16 04:24	10/14/16 09:45
10366518035	Room 630/Sink	Water	10/08/16 04:25	10/14/16 09:45
10366518036	Room 632/Sink	Water	10/08/16 04:25	10/14/16 09:45
10366518037	Room 631/Sink	Water	10/08/16 04:26	10/14/16 09:45

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366518038	Room 626/Sink	Water	10/08/16 04:27	10/14/16 09:45
10366518039	Room 621/Sink	Water	10/08/16 04:32	10/14/16 09:45
10366518040	Room 622/Sink	Water	10/08/16 04:32	10/14/16 09:45
10366518041	Room 623/Sink	Water	10/08/16 04:31	10/14/16 09:45
10366518042	Room 624/Sink	Water	10/08/16 04:30	10/14/16 09:45

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10366518001	Room 508/Sink	EPA 200.8	TT3	1	PASI-M
10366518002	Room 512/Sink	EPA 200.8	TT3	1	PASI-M
10366518003	Room 510/Sink	EPA 200.8	TT3	1	PASI-M
10366518004	Room 518/Sink	EPA 200.8	TT3	1	PASI-M
10366518005	Room 515/Sink	EPA 200.8	TT3	1	PASI-M
10366518006	Utility Sink Across From Nurse	EPA 200.8	TT3	1	PASI-M
10366518007	Room 516/Sink	EPA 200.8	TT3	1	PASI-M
10366518008	Room 503/Sink	EPA 200.8	TT3	1	PASI-M
10366518009	Room 409/Sink	EPA 200.8	TT3	1	PASI-M
10366518010	Room 411/Sink	EPA 200.8	TT3	1	PASI-M
10366518011	Room 414/Sink	EPA 200.8	TT3	1	PASI-M
10366518012	Room 415/Sink	EPA 200.8	TT3	1	PASI-M
10366518013	D.F. By Room 415	EPA 200.8	TT3	1	PASI-M
10366518014	Room 416/Sink	EPA 200.8	TT3	1	PASI-M
10366518015	Room 417/Sink	EPA 200.8	TT3	1	PASI-M
10366518016	Room 400/Sink	EPA 200.8	TT3	1	PASI-M
10366518017	Room 402/Sink	EPA 200.8	TT3	1	PASI-M
10366518018	Room 430/Sink	EPA 200.8	TT3	1	PASI-M
10366518019	Room 431/Sink	EPA 200.8	TT3	1	PASI-M
10366518020	Room 432/Sink	EPA 200.8	TT3	1	PASI-M
10366518021	Room 421/Sink	EPA 200.8	TT3	1	PASI-M
10366518022	Room 422/Sink	EPA 200.8	TT3	1	PASI-M
10366518023	Room 423/Sink	EPA 200.8	TT3	1	PASI-M
10366518024	Room 424/Sink	EPA 200.8	TT3	1	PASI-M
10366518025	D.F. By Room 424	EPA 200.8	TT3	1	PASI-M
10366518026	Room 426/Sink	EPA 200.8	TT3	1	PASI-M
10366518027	Room 600/Sink	EPA 200.8	TT3	1	PASI-M
10366518028	Room 604/Sink	EPA 200.8	TT3	1	PASI-M
10366518029	Room 614/Sink	EPA 200.8	TT3	1	PASI-M
10366518030	Room 615/Sink	EPA 200.8	TT3	1	PASI-M
10366518031	Room 616/Sink	EPA 200.8	TT3	1	PASI-M
10366518032	Room 617/Sink	EPA 200.8	TT3	1	PASI-M
10366518033	Room 612/Sink	EPA 200.8	TT3	1	PASI-M
10366518034	Room 610/Sink	EPA 200.8	TT3	1	PASI-M
10366518035	Room 630/Sink	EPA 200.8	TT3	1	PASI-M
10366518036	Room 632/Sink	EPA 200.8	TT3	1	PASI-M
10366518037	Room 631/Sink	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10366518038	Room 626/Sink	EPA 200.8	TT3	1	PASI-M
10366518039	Room 621/Sink	EPA 200.8	TT3	1	PASI-M
10366518040	Room 622/Sink	EPA 200.8	TT3	1	PASI-M
10366518041	Room 623/Sink	EPA 200.8	TT3	1	PASI-M
10366518042	Room 624/Sink	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Sample: Room 508/Sink		Lab ID: 10366518001	Collected: 10/08/16 04:06	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	7.0	ug/L	0.10	1		10/22/16 10:49	7439-92-1	
Sample: Room 512/Sink		Lab ID: 10366518002	Collected: 10/08/16 04:13	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	168	ug/L	0.10	1		10/22/16 10:54	7439-92-1	
Sample: Room 510/Sink		Lab ID: 10366518003	Collected: 10/08/16 04:07	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	19.1	ug/L	0.10	1		10/22/16 10:55	7439-92-1	
Sample: Room 518/Sink		Lab ID: 10366518004	Collected: 10/08/16 04:14	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	26.2	ug/L	0.10	1		10/22/16 10:56	7439-92-1	
Sample: Room 515/Sink		Lab ID: 10366518005	Collected: 10/08/16 04:10	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.0	ug/L	0.10	1		10/22/16 10:57	7439-92-1	
Sample: Utility Sink Across From Nurse		Lab ID: 10366518006	Collected: 10/08/16 04:11	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	19.2	ug/L	0.10	1		10/22/16 10:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

Sample: Room 516/Sink		Lab ID: 10366518007	Collected: 10/08/16 04:15	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	51.3	ug/L	0.10	1		10/22/16 11:00	7439-92-1	
Sample: Room 503/Sink		Lab ID: 10366518008	Collected: 10/08/16 04:34	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	10.0	ug/L	0.10	1		10/22/16 11:03	7439-92-1	
Sample: Room 409/Sink		Lab ID: 10366518009	Collected: 10/08/16 04:35	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.63	ug/L	0.10	1		10/22/16 11:04	7439-92-1	
Sample: Room 411/Sink		Lab ID: 10366518010	Collected: 10/08/16 04:35	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.7	ug/L	0.10	1		10/22/16 11:06	7439-92-1	
Sample: Room 414/Sink		Lab ID: 10366518011	Collected: 10/08/16 04:39	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.4	ug/L	0.10	1		10/22/16 11:07	7439-92-1	
Sample: Room 415/Sink		Lab ID: 10366518012	Collected: 10/08/16 04:37	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.48	ug/L	0.10	1		10/22/16 11:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Sample: D.F. By Room 415		Lab ID: 10366518013	Collected: 10/08/16 04:40	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.28	ug/L	0.10	1		10/22/16 11:11	7439-92-1	
Sample: Room 416/Sink		Lab ID: 10366518014	Collected: 10/08/16 04:36	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.49	ug/L	0.10	1		10/22/16 11:13	7439-92-1	
Sample: Room 417/Sink		Lab ID: 10366518015	Collected: 10/08/16 04:36	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.1	ug/L	0.10	1		10/22/16 11:14	7439-92-1	
Sample: Room 400/Sink		Lab ID: 10366518016	Collected: 10/08/16 04:41	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.47	ug/L	0.10	1		10/22/16 11:15	7439-92-1	
Sample: Room 402/Sink		Lab ID: 10366518017	Collected: 10/08/16 04:43	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.1	ug/L	0.10	1		10/22/16 11:18	7439-92-1	
Sample: Room 430/Sink		Lab ID: 10366518018	Collected: 10/08/16 04:45	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.4	ug/L	0.10	1		10/22/16 11:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Sample: Room 431/Sink		Lab ID: 10366518019	Collected: 10/08/16 04:45	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.1	ug/L	0.10	1		10/22/16 11:21	7439-92-1	
Sample: Room 432/Sink		Lab ID: 10366518020	Collected: 10/08/16 04:46	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.2	ug/L	0.10	1		10/22/16 11:22	7439-92-1	
Sample: Room 421/Sink		Lab ID: 10366518021	Collected: 10/08/16 04:53	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.92	ug/L	0.10	1		10/22/16 17:49	7439-92-1	
Sample: Room 422/Sink		Lab ID: 10366518022	Collected: 10/08/16 04:53	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.99	ug/L	0.10	1		10/22/16 17:53	7439-92-1	
Sample: Room 423/Sink		Lab ID: 10366518023	Collected: 10/08/16 04:52	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.57	ug/L	0.10	1		10/22/16 17:55	7439-92-1	
Sample: Room 424/Sink		Lab ID: 10366518024	Collected: 10/08/16 04:50	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.7	ug/L	0.10	1		10/22/16 17:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Sample: D.F. By Room 424		Lab ID: 10366518025	Collected: 10/08/16 04:51	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.16	ug/L	0.10	1		10/22/16 17:59	7439-92-1	
Sample: Room 426/Sink		Lab ID: 10366518026	Collected: 10/08/16 04:49	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.87	ug/L	0.10	1		10/22/16 18:00	7439-92-1	
Sample: Room 600/Sink		Lab ID: 10366518027	Collected: 10/08/16 04:17	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	19.8	ug/L	0.10	1		10/22/16 18:02	7439-92-1	
Sample: Room 604/Sink		Lab ID: 10366518028	Collected: 10/08/16 04:17	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.7	ug/L	0.10	1		10/22/16 18:03	7439-92-1	
Sample: Room 614/Sink		Lab ID: 10366518029	Collected: 10/08/16 04:22	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.5	ug/L	0.10	1		10/22/16 18:04	7439-92-1	
Sample: Room 615/Sink		Lab ID: 10366518030	Collected: 10/08/16 04:21	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.8	ug/L	0.10	1		10/22/16 18:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

Sample: Room 616/Sink		Lab ID: 10366518031	Collected: 10/08/16 04:20	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.5	ug/L	0.10	1		10/22/16 18:06	7439-92-1	
Sample: Room 617/Sink		Lab ID: 10366518032	Collected: 10/08/16 04:20	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.6	ug/L	0.10	1		10/22/16 18:09	7439-92-1	
Sample: Room 612/Sink		Lab ID: 10366518033	Collected: 10/08/16 04:22	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	14.7	ug/L	0.10	1		10/22/16 18:14	7439-92-1	
Sample: Room 610/Sink		Lab ID: 10366518034	Collected: 10/08/16 04:24	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.1	ug/L	0.10	1		10/22/16 18:15	7439-92-1	
Sample: Room 630/Sink		Lab ID: 10366518035	Collected: 10/08/16 04:25	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	11.5	ug/L	0.10	1		10/22/16 18:17	7439-92-1	
Sample: Room 632/Sink		Lab ID: 10366518036	Collected: 10/08/16 04:25	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.9	ug/L	0.10	1		10/22/16 18:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 16 2nd Floor
Pace Project No.: 10366518

Sample: Room 631/Sink		Lab ID: 10366518037	Collected: 10/08/16 04:26	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.8	ug/L	0.10	1		10/22/16 18:19	7439-92-1	
Sample: Room 626/Sink		Lab ID: 10366518038	Collected: 10/08/16 04:27	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	17.1	ug/L	0.10	1		10/22/16 18:20	7439-92-1	
Sample: Room 621/Sink		Lab ID: 10366518039	Collected: 10/08/16 04:32	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.2	ug/L	0.10	1		10/22/16 18:21	7439-92-1	
Sample: Room 622/Sink		Lab ID: 10366518040	Collected: 10/08/16 04:32	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.5	ug/L	0.10	1		10/22/16 18:23	7439-92-1	
Sample: Room 623/Sink		Lab ID: 10366518041	Collected: 10/08/16 04:31	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.9	ug/L	0.10	1		10/22/16 12:11	7439-92-1	
Sample: Room 624/Sink		Lab ID: 10366518042	Collected: 10/08/16 04:30	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.5	ug/L	0.10	1		10/22/16 12:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

QC Batch: 442007 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10366518001, 10366518002, 10366518003, 10366518004, 10366518005, 10366518006, 10366518007, 10366518008, 10366518009, 10366518010, 10366518011, 10366518012, 10366518013, 10366518014, 10366518015, 10366518016, 10366518017, 10366518018, 10366518019, 10366518020

METHOD BLANK: 2407280 Matrix: Water
 Associated Lab Samples: 10366518001, 10366518002, 10366518003, 10366518004, 10366518005, 10366518006, 10366518007, 10366518008, 10366518009, 10366518010, 10366518011, 10366518012, 10366518013, 10366518014, 10366518015, 10366518016, 10366518017, 10366518018, 10366518019, 10366518020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/22/16 10:35	

LABORATORY CONTROL SAMPLE: 2407281

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	92.3	92	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2412609 2412610

Parameter	Units	10366518001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	7.0	100	100	101	102	94	95	70-130	1	20	

MATRIX SPIKE SAMPLE: 2412611

Parameter	Units	10366518011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.4	100	98.1	95	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

QC Batch: 442008 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10366518021, 10366518022, 10366518023, 10366518024, 10366518025, 10366518026, 10366518027, 10366518028, 10366518029, 10366518030, 10366518031, 10366518032, 10366518033, 10366518034, 10366518035, 10366518036, 10366518037, 10366518038, 10366518039, 10366518040

METHOD BLANK: 2407283 Matrix: Water
 Associated Lab Samples: 10366518021, 10366518022, 10366518023, 10366518024, 10366518025, 10366518026, 10366518027, 10366518028, 10366518029, 10366518030, 10366518031, 10366518032, 10366518033, 10366518034, 10366518035, 10366518036, 10366518037, 10366518038, 10366518039, 10366518040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/22/16 17:44	

LABORATORY CONTROL SAMPLE: 2407284

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2412756 2412757

Parameter	Units	10366518021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	0.92	100	100	101	98.9	100	98	70-130	2	20	

MATRIX SPIKE SAMPLE: 2412758

Parameter	Units	10366518031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.5	100	102	100	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

QC Batch: 442009	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10366518041, 10366518042	

METHOD BLANK: 2407289 Matrix: Water

Associated Lab Samples: 10366518041, 10366518042

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/22/16 12:00	

LABORATORY CONTROL SAMPLE: 2407290

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2412638 2412639

Parameter	Units	10366502041		2412638		2412639		% Rec Limits	RPD	Max RPD	Qual
		MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec				
Lead	ug/L	2.2	100	100	105	103	103	101	70-130	2	20

MATRIX SPIKE SAMPLE: 2412640

Parameter	Units	10366530007 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	12.4	100	111	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: NYSD - BLDG 16 2nd Floor

Pace Project No.: 10366518

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: NYS - BLDG 16 2nd Floor

Pace Project No.: 10366518

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10366518001	Room 508/Sink	EPA 200.8	442007		
10366518002	Room 512/Sink	EPA 200.8	442007		
10366518003	Room 510/Sink	EPA 200.8	442007		
10366518004	Room 518/Sink	EPA 200.8	442007		
10366518005	Room 515/Sink	EPA 200.8	442007		
10366518006	Utility Sink Across From Nurse	EPA 200.8	442007		
10366518007	Room 516/Sink	EPA 200.8	442007		
10366518008	Room 503/Sink	EPA 200.8	442007		
10366518009	Room 409/Sink	EPA 200.8	442007		
10366518010	Room 411/Sink	EPA 200.8	442007		
10366518011	Room 414/Sink	EPA 200.8	442007		
10366518012	Room 415/Sink	EPA 200.8	442007		
10366518013	D.F. By Room 415	EPA 200.8	442007		
10366518014	Room 416/Sink	EPA 200.8	442007		
10366518015	Room 417/Sink	EPA 200.8	442007		
10366518016	Room 400/Sink	EPA 200.8	442007		
10366518017	Room 402/Sink	EPA 200.8	442007		
10366518018	Room 430/Sink	EPA 200.8	442007		
10366518019	Room 431/Sink	EPA 200.8	442007		
10366518020	Room 432/Sink	EPA 200.8	442007		
10366518021	Room 421/Sink	EPA 200.8	442008		
10366518022	Room 422/Sink	EPA 200.8	442008		
10366518023	Room 423/Sink	EPA 200.8	442008		
10366518024	Room 424/Sink	EPA 200.8	442008		
10366518025	D.F. By Room 424	EPA 200.8	442008		
10366518026	Room 426/Sink	EPA 200.8	442008		
10366518027	Room 600/Sink	EPA 200.8	442008		
10366518028	Room 604/Sink	EPA 200.8	442008		
10366518029	Room 614/Sink	EPA 200.8	442008		
10366518030	Room 615/Sink	EPA 200.8	442008		
10366518031	Room 616/Sink	EPA 200.8	442008		
10366518032	Room 617/Sink	EPA 200.8	442008		
10366518033	Room 612/Sink	EPA 200.8	442008		
10366518034	Room 610/Sink	EPA 200.8	442008		
10366518035	Room 630/Sink	EPA 200.8	442008		
10366518036	Room 632/Sink	EPA 200.8	442008		
10366518037	Room 631/Sink	EPA 200.8	442008		
10366518038	Room 626/Sink	EPA 200.8	442008		
10366518039	Room 621/Sink	EPA 200.8	442008		
10366518040	Room 622/Sink	EPA 200.8	442008		
10366518041	Room 623/Sink	EPA 200.8	442009		
10366518042	Room 624/Sink	EPA 200.8	442009		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10846518

Page: **1** of **4**

Section A

Required Client Information:
 Company: NYS School for the Deaf
 Address: 104 Turin Rd
 Rome, NY
 Email To: michael.ananiano@nysed.gov
 Phone: _____ Fax: _____
 Requested Due Date/TAT: _____

Section B

Required Project Information:
 Report To: _____
 Copy To: _____
 Purchase Order No.: _____
 Project Name: BLDG 16-10th FLOOR
 Project Number: 2nd

Section C

Invoice Information:
 Attention: _____
 Company Name: _____
 Address: _____
 Pace Quote Reference: _____
 Pace Project Manager: _____
 Pace Profile #: _____

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

SITE LOCATION
 GA IL IN MI NC
 OH SC WI OTHER_NY
 Filtered (Y/N) _____

ITEM #	Section D Required Client Information SAMPLE ID (A-Z, 0-9 / -) Sample IDs MUST BE UNIQUE	Valid Matrix Codes MATRIX CODE DWB WT WW P S S S S S S S	MATRIX CODE	SAMPLE TYPE G=GRAB C=COMP	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Requested Analytes	Resistant Chelate (Y/N)	Pace Project No. Lab I.D.				
					COMPOSITE START		COMPOSITE END/GRAB				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O8	Methanol	Na2SO4							
					DATE	TIME	DATE	TIME																	
1	ROOM 508/SINK		DWB	G			10/8	4:06	1		1							X							W1
2	ROOM 512/SINK							4:18	4:35	1		1						X							W2
3	ROOM 510/SINK							4:07		1		1						X							W3
4	ROOM 518/SINK							4:14		1		1						X							W4
5	ROOM 515/SINK							4:10		1		1						X							W5
6	UTILITY SINK ACROSS FROM NURSES STATION							4:11		1		1						X							W6
7	ROOM 516/SINK							4:15		1		1						X							W7
8	ROOM 503/SINK							4:34		1		1						X							W8
	ROOM 409/SINK							4:35																	W9
	ROOM 411/SINK							4:35																	010
11	ROOM 414/SINK							4:34		1		1						X							011
12	ROOM 415/SINK							4:37		1		1						X							012

REQUISITIONED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
James Murphy PACE	10/8/16	18:30	James Murphy PACE	10/14/16	945	18.8	Y/N	Y/N	Y/N
							Y/N	Y/N	Y/N
							Y/N	Y/N	Y/N

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy - PACE Analytical
 SIGNATURE OF SAMPLER: *James Murphy*
 DATE Signed (MM / DD / YY): 10/8/16

Temp in °C	Received on Ice	Custody Sealed Cooler	Samples Intact



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 2 of 4

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: NYS School for the Deaf		Report To:		Attention:	
Address: 104 Turin Rd		Copy To:		Company Name:	
Rome, NY				Address:	
Email To: michael.ananiano@nysed.gov		Purchase Order No.:		Pace Quote Reference:	
Phone: Fax:		Project Name: BLDG 16-16 ^T FLOOR 2 nd		Pace Project Manager:	
Requested Due Date/TAT:		Project Number:		Pace Profile #:	

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER

UST RCRA OTHER _____

SITE LOCATION

GA IL IN MI NC
 OH SC WI OTHER NY

Filtered (Y/N)

ITEM #	Section D Required Client Information SAMPLE ID (A-Z, 0-9 / . -) Sample IDs MUST BE UNIQUE	Valid Matrix Codes MATRIX CODE DW WT WW WASTE WATER PRODUCT COLLECOD OIL WIPE AIR OTHER TISSUE	MATRIX CODE	SAMPLE TYPE G=GRAB C=COMP	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Requested Analysis												Pace Project No. Lab I.D.						
					COMPOSITE START		COMPOSITE END/GRAB				Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ SO ₃	Methanol	Na ₂ SO ₄	Requested Analysis																	
					DATE	TIME	DATE	TIME																												
1	DF. 34 ROOM 415		DU 6		10/13	4:40			1								X																			013
2	Room 416/SINK					4:36			1								X																		014	
3	Room 417/SINK					4:36			1								X																		015	
4	Room 400/SINK					4:41			1								X																		016	
5	Room 402/SINK					4:43			1								X																		017	
6	Room 430/SINK					4:45			1								X																		018	
7	Room 431/SINK					4:45			1								X																		019	
8	Room 432/SINK					4:46			1								X																		020	
	Room 421/SINK					4:53																													021	
	Room 422/SINK					4:52																														022
11	Room 423/SINK					4:52			1								X																		023	
12	Room 424/SINK					4:50			1								X																		024	

DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
10/13/16	18:30	James Murphy PACE	10/14/16	9:45	18.5	Y/N	Y/N	Y/N
						Y/N	Y/N	Y/N
						Y/N	Y/N	Y/N
						Y/N	Y/N	Y/N

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: James Murphy - PACE Analytical

SIGNATURE of SAMPLER: *James Murphy*

DATE Signed (MM / DD / YY): 10/8/16

Temp in °C: _____

Received on Ice:

Custody Sealed Cooler:

Samples Intact:



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: **3** of **4**

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: NYS School for the Deaf		Report To:		Attention:	
Address: 104 Turin Rd		Copy To:		Company Name:	
Rome, NY				Address:	
Email To: michael.ananiano@nysed.gov		Purchase Order No.:		Pace Quote Reference:	
Phone: Fax:		Project Name: BLDG 16-10 th FLOOR 2 nd		Pace Project Manager:	
Requested Due Date/TAT:		Project Number:		Pace Profile #:	

REGULATORY AGENCY	
<input type="checkbox"/> NPDES	<input type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER
<input type="checkbox"/> UST	<input type="checkbox"/> RCRA <input type="checkbox"/> OTHER _____
SITE LOCATION	<input type="checkbox"/> GA <input type="checkbox"/> IL <input type="checkbox"/> IN <input type="checkbox"/> MI <input type="checkbox"/> NC <input type="checkbox"/> OH <input type="checkbox"/> SC <input type="checkbox"/> WI <input type="checkbox"/> OTHER_NY_
Filtered (Y/N)	

ITEM #	Section D Required Client Information SAMPLE ID (A-Z, 0-9 / -) Sample IDs MUST BE UNIQUE	Valid Matrix Codes		COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Requested Analytes	Pace Project No. Lab I.D.
		MATRIX	CODE	COMPOSITE		DATE	TIME			Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₅	Methanol	Na ₂ SO ₄		
		DRINKING WATER	DW	START	END/GRAB														
		WATER	WW	PRODUCT	P														
1	DF BY ROOM 424	DW	G			10/8	4:51	1			1						X	025	
2	Room 426 / SINK						4:49	1			1						X	026	
3	Room 600 / SINK						4:17	1			1						X	027	
4	Room 604 / SINK						4:17	1			1						X	028	
5	Room 614 / SINK						4:22	1			1						X	029	
6	Room 615 / SINK						4:21	1			1						X	030	
7	Room 616 / SINK						4:20	1			1						X	031	
8	Room 617 / SINK						4:20	1			1						X	032	
	Room 612 / SINK						4:22											033	
	Room 610 / SINK						4:24											034	
11	Room 630 / SINK						4:25	1			1						X	035	
12	Room 632 / SINK						4:21	1			1						X	036	

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
James Murphy PACE	10/13/16	10:30	James Murphy PACE	10/14/16	945	X	Y	Y	Y
							Y	Y	Y
							Y	Y	Y
							Y	Y	Y

SAMPLER NAME AND SIGNATURE		Temp in °C	Received on Ice	Custody Sealed Cooler	Samples intact
PRINT Name of SAMPLER: James Murphy - PACE Analytical					
SIGNATURE of SAMPLER: James Murphy					
DATE Signed (MM / DD / YY): 10/16/16					

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A

Required Client Information:

Company: NYS School for the Deaf
Address: 104 Turin Rd
Rome, NY
Email To: michael.ananiano@nysed.gov
Phone: _____ Fax: _____
Requested Due Date/TAT: _____

Section B

Required Project Information:

Report To: _____
Copy To: _____
Purchase Order No.: _____
Project Name: BLDG 16-1ST FLOOR
Project Number: 2112

Section C

Invoice Information:

Attention: _____
Company Name: _____
Address: _____
Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

SITE LOCATION

GA IL IN MI NC
 OH SC WI OTHER_NY _____

ITEM #	Section D Required Client Information SAMPLE ID (A-Z, 0-9 / -) Sample IDs MUST BE UNIQUE	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WATER WW WASTE WATER PRODUCT P SOIL/SOLID SL OIL OL WASTE WP AIR AR OTHER OT TISSUE TS	MATRIX CODE	SAMPLE TYPE G=GRAB C=COMP	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Filtered (Y/N)	Requested Amt	Residual Chlorine (Y/N)	Pace Project No. Lab I.D.											
					COMPOSITE START		COMPOSITE END/GRAB				Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₃	Methanol	Na ₂ SO ₄															
					DATE	TIME	DATE	TIME																									
1	Room 631 / SINK		D1	G			10/8	4:24	1			1																					037
2	Room 626 / SINK							4:27	1			1																					038
3	Room 621 / SINK							4:32	1			1																					039
4	Room 622 / SINK							4:32	1			1																					040
5	Room 623 / SINK							4:31	1			1																					041
6	Room 624 / SINK							4:30	1			1																					042
7									1			1																					
8									1			1																					
9									1			1																					
10									1			1																					
11									1			1																					
12									1			1																					

REINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
<i>James Murphy PACE</i>	10/13/16	12:30	<i>[Signature]</i> PACE	10/14/16	9:45	15.8	<input checked="" type="checkbox"/> Y	<input checked="" type="checkbox"/> Y	<input checked="" type="checkbox"/> Y
							<input type="checkbox"/> Y	<input type="checkbox"/> Y	<input type="checkbox"/> Y
							<input type="checkbox"/> Y	<input type="checkbox"/> Y	<input type="checkbox"/> Y
							<input type="checkbox"/> Y	<input type="checkbox"/> Y	<input type="checkbox"/> Y

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: James Murphy - PACE Analytical

SIGNATURE of SAMPLER: *[Signature]*


DATE Signed (MM / DD / YY): 10/13/16

Temp in °C: _____

Received on ice:

Custody Sealed Cooler:

Samples Intact:


	Document Name: Sample Condition Upon Receipt Form	Document Revised: 02Aug2016 Page 1 of 2
	Document No.: F-MN-L-213-rev.17	Issuing Authority: Pace Minnesota Quality Office

Sample Condition Upon Receipt **Client Name:** NYS School for the Deaf - Pace NY **Project #:** **WO#: 10366518**

Courier: Fed Ex UPS USPS Client
 Commercial Pace Speedee Other: _____

Tracking Number: 7774 6734 7854

WO#: 10366518



10366518

Custody Seal on Cooler/Box Present? Yes No **Seals Intact?** Yes No **Optional:** Proj. Due Date: _____ Proj. Name: _____

Packing Material: Bubble Wrap Bubble Bags None Other: _____ **Temp Blank?** Yes No

Thermometer 151401163 B88A912167504 **Type of Ice:** Wet Blue None Samples on ice, cooling process has begun
Used: 151401164 B88A0143310098

Cooler Temp Read (°C): 18.8 **Cooler Temp Corrected (°C):** 19.0 **Biological Tissue Frozen?** Yes No N/A
Temp should be above freezing to 6°C **Correction Factor:** 10.2 **Date and Initials of Person Examining Contents:** SNL 10/19/16

USDA Regulated Soil (N/A, water sample)
Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? Yes No Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	1.
Chain of Custody Filled Out? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	2.
Chain of Custody Relinquished? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	3.
Sampler Name and/or Signature on COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	5.
Short Hold Time Analysis (<72 hr)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	6.
Rush Turn Around Time Requested? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	7.
Sufficient Volume? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	8.
Correct Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	9.
-Pace Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	10.
Filtered Volume Received for Dissolved Tests? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	12.
-Includes Date/Time/ID/Analysis Matrix: <u>water</u>	
All containers needing acid/base preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH>9 Sulfide, NaOH>12 Cyanide) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Sample # 1/1 1-42
Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: _____ Lot # of added preservative: _____
Headspace in VOA Vials (>6mm)? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
Trip Blank Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Custody Seals Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if purchased): _____	

CLIENT NOTIFICATION/RESOLUTION **Field Data Required?** Yes No

Person Contacted: _____ Date/Time: _____

Comments/Resolution: Temp OK

Project Manager Review: Amanda J. Albrecht **Date:** 10/19/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).